

Inspection Practices for Piping System Components

API RECOMMENDED PRACTICE 574
FIFTH EDITION, FEBRUARY 2024

ADDENDUM 1, MARCH 2025



American
Petroleum
Institute

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed. The use of API publications is voluntary. In some cases, third parties or authorities having jurisdiction may choose to incorporate API standards by reference and may mandate compliance.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to ensure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Copyright © 2024 American Petroleum Institute

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

The verbal forms used to express the provisions in this document are as follows.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the standard.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the standard.

May: As used in a standard, “may” denotes a course of action permissible within the limits of a standard.

Can: As used in a standard, “can” denotes a statement of possibility or capability.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Suite 1100, Washington, DC 20001, standards@api.org.

Contents

1	Scope.....	1
2	Normative References	1
3	Terms, Definitions, Acronyms, and Abbreviations	1
3.1	Terms and Definitions	1
3.2	Acronyms and Abbreviations	11
4	Introduction to Piping.....	12
4.1	Piping Components	12
4.2	Tubing	14
4.3	Valves	14
4.4	Fittings	22
4.5	Flanges.....	25
4.6	Expansion Joints	25
4.7	Piping Supports	26
4.8	Flexible Hoses	27
5	Piping Design and Construction	27
5.1	Design and Construction Standards.....	27
5.2	Methods of Construction.....	28
5.3	Materials of Construction.....	34
6	Reasons for Inspection	37
6.1	General	37
6.2	Process and Personnel Safety	37
6.3	Regulatory Requirements	37
6.4	Reliable Operation	38
7	Inspection and Monitoring Planning.....	38
7.1	Background	38
7.2	Developing an Inspection Plan	38
7.3	Monitoring Process Piping	44
7.4	Inspection Guidance for Location-specific Damage	49
7.5	Inspection Guidance for Specific Damage Mechanisms	67
7.6	Reviewing and Updating Inspection Plans.....	73
7.7	IOWs	73
7.8	Inspection of New Fabrication	74
7.9	Newly Commissioned Piping Inspection.....	74
8	Strategies for Establishing Frequency of Inspection.....	76
8.1	Fixed Interval	76
8.2	RBI	77
8.3	Opportunities for Inspection.....	77
8.4	Inspection Scope	79
9	Safety Precautions and Preparatory Work.....	79
9.1	Safety Precautions	79
9.2	Communication	80
9.3	Preparatory Work	80
9.4	Cleaning and Surface Preparation for Inspection	82
9.5	Investigation of Active Leaks	82
10	Inspection Types, Methods, and Limitations	83
10.1	External Visual Inspection	83
10.2	Internal Visual Inspection	90
10.3	Specific Areas or Components for Inspection.....	92
10.4	Thickness Measurements	98

10.5	Determination of Minimum Required Thickness	106
10.6	Other Inspection Methods/Techniques.....	110
10.7	Nonmetallic Piping.....	113
11	Inspection Results	114
11.1	Evaluation of Inspection Results	114
11.2	Determination of Follow-up Actions	115
11.3	Using Fitness-For-Service.....	116
12	Rerating and Repair	116
12.1	Rerating of Piping System	116
12.2	Repairing Pipe Damage	118
13	Pressure Tests	119
13.1	Purpose of Testing.....	119
13.2	Types of Pressure Tests.....	120
13.3	Performing Pressure Tests	120
13.4	Pressure Testing Considerations.....	122
13.5	Pressure Test Safety Considerations	122
14	Records and Reports.....	123
14.1	General	123
14.2	Records	124
14.3	Reports.....	127
Annex A	(informative) External Inspection Checklist for Process Piping	128
Annex B	(informative) Tables of Pipe Schedules	129
Annex C	(informative) Statistical Analysis of Circuit Thickness Data	136
Annex D	(informative) Example Minimum Structural Thicknesses Tables	139
Bibliography		147

Figures

1	Cross Section of a Typical Wedge Gate Valve.....	16
2	Cross Section of a Typical Globe Valve	17
3	Cross Sections of Typical Lubricated and Nonlubricated Plug Valves	18
4	Cross Section of a Typical Ball Valve	19
5	Cross Section of a Typical Diaphragm Valve.....	19
6	Typical Butterfly Valve.....	20
7	Cross Sections of Typical Check Valves.....	21
8	Cross Section of a Typical Slide Valve	23
9	Flanged-end Fittings and Wrought Steel Butt-welded Fittings	24
10	Forged Steel Threaded and Socket-welded Fittings	25
11	Cross Section of a Socket-welded Tee Connection	29
12	Flange Facings Commonly Used in Refinery and Chemical Plant Piping	30
13	Types of Flanges.....	31
14	Cross Section of a Typical Bell-and-Spigot Joint.....	31
15	Cross Sections of Typical Packed and Sleeve Joints	32
16	Cross Sections of Typical Tubing Joints	33
17	Erosion of Piping	40
18	Corrosion of Piping.....	41
19	Internal Corrosion of Piping	41
20	Severe Atmospheric Corrosion of Piping.....	42
21	Piping Circuit Example	48
22	SAI Corrosion	54
23	Underground Piping Corrosion beneath Poorly Applied Tape Wrap	58
24	Pipe-to-Soil Internal Potential Survey Use to Identify Active Corrosion.....	59

25	Example of Pipe-to-Soil Potential Survey Chart	60
26	Wenner Four-pin Soil Resistivity Test	62
27	Soil Bar Used for Soil Resistivity Measurements	63
28	Two Types of Soil Boxes Used for Soil Resistivity Measurements	64
29	Case of Doubling due to Mode Converted Shear Wave Echo Occurring between the Backwall Echoes	102
30	Example of Screen Display of UT Thickness Gauge with Automatic Temperature Compensation	103
31	Radiograph of a Catalytic Reformer Line	105
32	Radiograph of Corroded Pipe Whose Internal Surface Is Coated with Iron Sulfide Scale	105
33	Sketch and Radiograph of Dead-end (Deadleg) Corrosion	105
34	Typical Isometric Sketch	125
35	Typical Tabulation of Thickness Data	126

Tables

1	API and ASME Valve Design Standards and Codes	15
2	Mix Point Thermal Fatigue Screening Criteria	52
3	Damage Mechanisms Associated with Nonmetallic Piping	72
4	Table 2 of API 570	90
5	Comparison of Common Nonmetallic Piping NDE Techniques	114
B.1	Nominal Pipe Sizes, Schedules, Weight Classes, and Dimensions of Ferritic Steel Pipe	129
B.2	Nominal Pipe Sizes, Schedules, and Dimensions of Stainless Steel Pipe	133
B.3	Permissible Tolerances in Diameter and Thickness for Ferritic Pipe	135
D.1	Maximum Span Lengths	140
D.2a	Carbon Steel Minimum Structural Thickness (in.) at 400 °F (205 °C)	141
D.2b	Carbon Steel Minimum Structural Thickness (mm) at 400 °F (205 °C)	141
D.2c	Carbon Steel Minimum Structural Thickness (in.) at 750 °F (400 °C)	142
D.2d	Carbon Steel Minimum Structural Thickness (mm) at 750 °F (400 °C)	142
D.3a	Austenitic Stainless Steel Minimum Structural Thickness (in.) at 400 °F (205 °C)	143
D.3b	Austenitic Stainless Steel Minimum Structural Thickness (mm) at 400 °F (205 °C)	143
D.3c	Austenitic Stainless Steel Minimum Structural Thickness (in.) at 1000 °F (540 °C)	144
D.3d	Austenitic Stainless Steel Minimum Structural Thickness (mm) at 1000 °F (540 °C)	144
D.4a	1-1/4Cr-1/2Mo Minimum Structural Thickness (in.) at 750 °F (400 °C)	145
D.4b	1-1/4Cr-1/2Mo Minimum Structural Thickness (mm) at 750 °F (400 °C)	145
D.4c	1-1/4Cr-1/2Mo Minimum Structural Thickness (in.) at 1100 °F (595 °C)	146
D.4d	1-1/4Cr-1/2Mo Minimum Structural Thickness (mm) at 1100 °F (595 °C)	146

Inspection Practices for Piping System Components

1 Scope

This recommended practice supplements API 570 by providing piping inspectors with information that can improve their skills and increase their basic knowledge of inspection practices. This recommended practice describes inspection practices for piping, tubing, valves (other than control valves), and fittings used in petroleum refineries and chemical plants. Common piping components, valve types, pipe joining methods, inspection planning processes, inspection intervals and techniques, and types of records are described to aid the inspectors in fulfilling their role in implementing API 570. This publication does not cover the inspection of specialty items, including instrumentation, furnace tubulars, and control valves.

2 Normative References

The following documents are referred to in the text in such a way that some or all their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document, including any addenda, applies.

API 570, *Piping Inspection Code: In-service Inspection, Rating, Repair, and Alteration of Piping Systems*

API Recommended Practice 571, *Damage Mechanisms Affecting Fixed Equipment in the Refining Industry*

API Recommended Practice 578, *Material Verification Program for New and Existing Assets*

API 579-1/ASME FFS-1 ¹, *Fitness-For-Service*

API Recommended Practice 580, *Elements of a Risk-based Inspection Program*

ASME B16.20, *Metallic Gaskets for Pipe Flanges*

ASME B16.25, *Buttwelding Ends*

ASME B16.34, *Valves—Flanged, Threaded, and Welding End*

ASME B31.3, *Process Piping*

ASME Boiler and Pressure Vessel Code (BPVC), *Section V: Nondestructive Examination*

ASTM G57 ², *Standard Test Method for Measurement of Soil Resistivity Using the Wenner Four-Electrode Method*

3 Terms, Definitions, Acronyms, and Abbreviations

For the purposes of this document, the following terms and definitions apply.

NOTE Definitions for terms delineated with asterisks are maintained by API 574. If another document plans to reference, see API Bulletin 590 for reference.

3.1 Terms and Definitions

3.1.1

alloy material

Any metallic material (including welding filler materials) that contains alloying elements, such as chromium, nickel, or molybdenum, which are intentionally added to enhance mechanical or physical properties and/or corrosion resistance.

¹ American Society of Mechanical Engineers, Two Park Avenue, New York, New York 10016, www.asme.org.

² ASTM International, 100 Barr Harbor Drive, West Conshohocken, Pennsylvania 19428, www.astm.org.