

Petroleum, Petrochemical, and Natural Gas Industries—Air-cooled Heat Exchangers

API STANDARD 661
SEVENTH EDITION, JULY 2013

REAFFIRMED, JULY 2024



American
Petroleum
Institute

Special Notes

API publications necessarily address problems of a general nature. With respect to particular circumstances, local, state, and federal laws and regulations should be reviewed.

Neither API nor any of API's employees, subcontractors, consultants, committees, or other assignees make any warranty or representation, either express or implied, with respect to the accuracy, completeness, or usefulness of the information contained herein, or assume any liability or responsibility for any use, or the results of such use, of any information or process disclosed in this publication. Neither API nor any of API's employees, subcontractors, consultants, or other assignees represent that use of this publication would not infringe upon privately owned rights.

Users of this standard should not rely exclusively on the information contained in this document. Sound business, scientific, engineering, and safety judgment should be used in employing the information contained herein.

Work sites and equipment operations may differ. Users are solely responsible for assessing their specific equipment and premises in determining the appropriateness of applying the standard. At all times users should employ sound business, scientific, engineering, and judgment safety when using this standard.

API publications may be used by anyone desiring to do so. Every effort has been made by the Institute to assure the accuracy and reliability of the data contained in them; however, the Institute makes no representation, warranty, or guarantee in connection with this publication and hereby expressly disclaims any liability or responsibility for loss or damage resulting from its use or for the violation of any authorities having jurisdiction with which this publication may conflict.

API publications are published to facilitate the broad availability of proven, sound engineering and operating practices. These publications are not intended to obviate the need for applying sound engineering judgment regarding when and where these publications should be utilized. The formulation and publication of API publications is not intended in any way to inhibit anyone from using any other practices.

Any manufacturer marking equipment or materials in conformance with the marking requirements of an API standard is solely responsible for complying with all the applicable requirements of that standard. API does not represent, warrant, or guarantee that such products do in fact conform to the applicable API standard.

All rights reserved. No part of this work may be reproduced, translated, stored in a retrieval system, or transmitted by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission from the publisher. Contact the Publisher, API Publishing Services, 200 Massachusetts Avenue, NW, Washington, DC 20001.

Copyright © 2013 American Petroleum Institute

Foreword

Nothing contained in any API publication is to be construed as granting any right, by implication or otherwise, for the manufacture, sale, or use of any method, apparatus, or product covered by letters patent. Neither should anything contained in the publication be construed as insuring anyone against liability for infringement of letters patent.

Shall: As used in a standard, “shall” denotes a minimum requirement in order to conform to the specification.

Should: As used in a standard, “should” denotes a recommendation or that which is advised but not required in order to conform to the specification.

This document was produced under API standardization procedures that ensure appropriate notification and participation in the developmental process and is designated as an API standard. Questions concerning the interpretation of the content of this publication or comments and questions concerning the procedures under which this publication was developed should be directed in writing to the Director of Standards, American Petroleum Institute, 200 Massachusetts Avenue, NW, Washington, DC 20001. Requests for permission to reproduce or translate all or any part of the material published herein should also be addressed to the director.

Generally, API standards are reviewed and revised, reaffirmed, or withdrawn at least every five years. A one-time extension of up to two years may be added to this review cycle. Status of the publication can be ascertained from the API Standards Department, telephone (202) 682-8000. A catalog of API publications and materials is published annually by API, 200 Massachusetts Avenue, NW, Washington, DC 20001.

Suggested revisions are invited and should be submitted to the Standards Department, API, 200 Massachusetts Avenue, NW, Washington, DC 20001, standards@api.org.

Contents

	Page
1 Scope	1
2 Normative References	1
3 Terms and Definitions	2
4 General	5
5 Proposals	7
6 Documentation	7
6.1 Approval Information	7
6.2 Final Records	9
7 Design	9
7.1 Tube Bundle Design	9
7.2 Air-side Design	23
7.3 Structural Design	35
8 Materials	39
8.1 General	39
8.2 Requirements for Carbon Steel in Sour or Wet Hydrogen Sulfide Service	40
8.3 Headers	40
8.4 Louvers	40
8.5 Other Components	41
9 Fabrication of Tube Bundle	41
9.1 Welding	41
9.2 Postweld Heat Treatment	42
9.3 Tube-to-Tubesheet Joints	42
9.4 Gasket Contact Surfaces	43
9.5 Thread Lubrication	44
9.6 Alignment and Tolerances	44
9.7 Assembly	44
10 Inspection, Examination, and Testing	44
10.1 Quality Control	44
10.2 Pressure Test	47
10.3 Shop Run-in	47
10.4 Equipment Performance Testing	47
10.5 Nameplates	47
11 Preparation for Shipment	48
11.1 General	48
11.2 Surfaces and Finishes	48
11.3 Identification and Notification	48
12 Supplemental Requirements	48
12.1 General	48
12.2 Design	49
12.3 Examination	49
12.4 Testing	50

Contents

	Page
Annex A (informative) Recommended Practices	51
Annex B (informative) Checklist and Data Sheets	58
Annex C (informative) Winterization of Air-cooled Heat Exchangers	69
Annex D (informative) Recommended Procedure for Airflow Measurement of Air-cooled Heat Exchangers	120
Annex E (informative) Measurement of Noise from Air-cooled Heat Exchangers	128
Bibliography	146

Figures

1 Typical Bay Arrangements	3
2 Typical Components of an Air-cooled Heat Exchanger	6
3 Typical Construction of Tube Bundles with Removable Cover Plate and Removable Bonnet Headers.	14
4 Typical Confined and Full-faced Gasket Joint Details	15
5 Typical Construction of a Tube Bundle with Plug Headers	16
6 Nozzle Loads	20
7 Fan Dispersion Angle	25
8 Typical Drive Arrangements	31
9 Typical Plenum Arrangements	38
10 Standard Tolerances	45
C.1 System A — Airflow Control with Variable Speed Drives or Automatically Controlled Variable-pitch Fans	76
C.2 System A — Airflow Control with Automatically Controlled Outlet Louvers and Fixed-pitch Fans	77
C.3 System B — Induced Draught with Non-contained Internal Air Recirculation	77
C.4 System B — Forced Draught with Non-contained Internal Air Recirculation	78
C.5 System C — Typical Forced-draught Air-cooled Heat Exchanger with Contained Internal Air Recirculation.	78
C.6 System D — Typical Forced-draught Air-cooled Heat Exchanger with External Air Recirculation.	79
C.7 Freezing Points of Phenol-water Solutions	84
C.8 Freezing Points of Ethanolamine-water Solutions	84
C.9 Freezing Points of Glycerol-water Solutions	85
C.10 Dissociation Constant of Ammonium Bisulfide (NH₄HS)	86
C.11 Hydrate Pressure-temperature Equilibria.	87
C.12 Tempered-water System.	98
D.1 Static Pressure Probe Locations	122
D.2 Location of Measurement Points.	123
E.1 Isolated Single Bay Noise Measurement Points	131
E.2 <i>L_p</i> Measurement Locations Forced — Draught Unit (2-fan Bay)	139
E.3 <i>L_p</i> Measurement Locations Induced — Draught Unit (2-fan Bay)	140

Tables

1 Minimum Nominal Thickness of Header Components	12
2 Minimum Flange Bolt Spacing	15
3 Minimum Nozzle Neck Nominal Thickness	18

Contents

	Page
4 Maximum Allowable Nozzle Loads	20
5 Minimum Required Wall Thickness of Tubes	21
6 Radial Clearances	26
7 Dry-air Standard Conditions	27
8 Minimum Thickness of Expanded Metal Fan Guard Mesh	28
9 Maximum Allowable Louver Deflection	33
10 Live Loads on Platforms, Columns and Walkways	36
11 Nominal Tube Hole Diameters and Tolerances	43
12 Maximum Weld Hardness	46
A.1 Maximum Fin Selection Temperature for Fin Bonding Types	52
A.2 Header Selection	53
A.3 Gasket Types	55
A.4 Gasket Contact-surface Finish	55
A.5 Service Conditions	56
A.6 Gasket Selection	56
C.1 Safety Margins for Different Process Categories	73
C.2 Freezing Points of Frequently Encountered Liquid Pure Components	83
C.3 Description of Indirect and Direct Air Cooling Systems (SI Units)	99
C.4 Description of Indirect and Direct Air Cooling Systems (US Customary Units)	99
C.5 Comparison of Costs of Indirect and Direct Air Cooling Systems	100
C.6 Values for r_m Referred to the Total Outside Area for a Tube with an Outside Diameter of 25.4 mm and Aluminum Fins 15.9 mm High and 0.4 mm Thick	102
C.7 Values for r_m Referred to the Total Outside Area for a Tube with an Outside Diameter of 1 in. and Aluminum Fins $\frac{5}{8}$ in. High and 0.016 in. Thick	106
D.1 Instruments	120
D.2 Location of Measurement Points	123
E.1 Required Instrumentation and Applicable Specifications	128
E.2 Symbols and Abbreviations	129
E.3 Isolated Single Bay Noise Measurement Points	132
E.4 Background Correction Values	133
E.5 Background Correction Values — Example for One Measurement Point “X”	133
E.6 Background Noise Correction Values	141
E.7 Background Noise Correction Values — Example Using One Measurement Point “X”	141
E.8 Background Noise Correction Values — Example Using Measurement Point “n”	141
E.9 Background Noise Correction Values	143
E.10 Background Noise Correction Values — Example Using One Measurement Point “X”	143
E.11 Background Noise Correction Values — Example Using Measurement Point “n”	143

Introduction

It is necessary that users of this standard be aware that further or differing requirements can be needed for individual applications. This standard is not intended to inhibit a Vendor from offering, or the Purchaser from accepting, alternative equipment or engineering solutions for the individual application. This can be particularly applicable where there is innovative or developing technology. Where an alternative is offered, it is the responsibility of the Vendor to identify any variations from this standard and provide details.

Petroleum, Petrochemical, and Natural Gas Industries—Air-cooled Heat Exchangers

1 Scope

This standard gives requirements and recommendations for the design, materials, fabrication, inspection, testing, and preparation for shipment of air-cooled heat exchangers for use in the petroleum, petrochemical, and natural gas industries.

This standard is applicable to air-cooled heat exchangers with horizontal bundles, but the basic concepts can also be applied to other configurations.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

AGMA 6001 ¹, *Design and Selection of Components for Enclosed Gear Drives*

ANSI/AGMA 6010, *Spur, Helical, Herringbone and Bevel Enclosed Drives*

ASME PTC 30 ², *Air-Cooled Heat Exchangers*

ICC ³, *International Building Code*

ISO 76 ⁴, *Rolling bearings — Static load ratings*

ISO 281, *Rolling bearings — Dynamic load ratings and rating life*

ISO 286 (all parts), *Geometrical product specifications (GPS) — ISO code system for tolerances on linear sizes*

ISO 1081, *Belt drive — V-belts and V-ribbed belts, and corresponding grooved pulleys — Vocabulary*

ISO 1461, *Hot-dip galvanized coatings on fabricated iron and steel articles — Specifications and test methods*

ISO 2491, *Thin parallel keys and their corresponding keyways (dimensions in millimeters)*

ISO 4183, *Belt drives — Classical and narrow V-belts — Grooved pulleys (system based on datum width)*

ISO 4184, *Belt drives — Classical and narrow V-belts — Lengths in datum system*

ISO 5287, *Belt drives — Narrow V-belts for the automotive industry — Fatigue test*

¹ American Gear Manufacturers Association, 1001 N. Fairfax Street, Suite 500, Alexandria, Virginia 22314, www.agma.org.

² American Society of Mechanical Engineers, Two Park Avenue, New York, NY 10016-5990, www.asme.org.

³ International Code Council, 500 New Jersey Avenue, NW, 6th Floor, Washington, DC 20001, www.iccsafe.org.

⁴ International Organization for Standardization, 1, ch. de la Voie-Creuse, Case postale 56, CH-1211, Geneva 20, Switzerland, www.iso.org.